

Update on Total Trihalomethane and Haloacetic Acid Sampling Results

In the 2017 Las Campanas Water Quality Report, the results for Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5) were reported as “NA” since the results are based on a location running annual average requiring a minimum of four quarters of testing. As mentioned in the 2017 Las Campanas Water Quality Report, the Coop would place the results on the webpage once they were available. On September 18, 2018, sampling for TTHMs and HAA5 were performed resulting in a locational running annual average below the Maximum Contaminant Level as detailed in the table below.

	TTHM (parts per billion)	HAA5 (parts per billion)
1 st Quarter	117	18.3
2 nd Quarter	42.6	8.28
3 rd Quarter	50.4	7.63
4 th Quarter	37.6	5.92
Locational Running Annual Average	61.9	10.03
Maximum Contaminants Level	80	60